

0419



0000078764

ORIGINAL TACNA WATER MANAGEMENT COMPANY

2993 S ARIZONA AVENUE YUMA, AZ 85365

2008 JUN 30 A 10:37

AZ CORP COMMISSION
DOCKET CONTROL

June 25
~~February 4~~, 2008

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

Arizona Corporation Commission
DOCKETED

JUN 30 2008

DOCKETED BY	<i>mn</i>
-------------	-----------

Re: Compliance Approval to construct, DOCKET NO. W-01344A-04-0815 and DECISION NO. 69208

Attached is our Approval to Construct . All equipment, lines, and valves are in place. We are ready to provide water service to Mohawk Utility's existing customers. We appreciate any help in this matter. If you have any questions please contact Steve Kelland or Don Kelland at 928-341-9885.

Sincerely
Don Kelland
Don Kelland
President



Yuma County, Arizona
DEPARTMENT OF DEVELOPMENT SERVICES

2351 W. 26th Street, Yuma, Arizona 85364

Phone: (928) 817-5000

Fax: (928) 817-5020

Monty M. Stansbury, AICP
Director


CERTIFICATE OF APPROVAL TO CONSTRUCT WATER FACILITIES

YCDDS FILE NO:	PR08-0154
SYSTEM NAME:	Tacna Water Company
SYSTEM NUMBER	14018
PROJECT NAME:	Tacna Water Company Improvements
PROJECT OWNER:	Don Kelland
OWNER'S ADDRESS:	2993 S. Arizona Avenue, Yuma, AZ. 85364
PROJECT LOCATION:	S. Avenue 38E and Pearl Drive
PROJECT DESCRIPTION:	Construct new 150 GPM well as a new source to existing drinking water distribution system

Approval to construct the above-described facilities, as represented in the approved plan documents on file at the Yuma County Department of Development Services (YCDDS), is hereby given subject to the following Provisions:

1. Notice shall be given to the Yuma County Department of Development Services when construction of the project begins to allow for inspection during construction per A.R.S. Section 49-104.B.10.
2. The Project Owner shall retain a professional engineer as soon as possible to provide detailed construction inspections of this project. Upon completion of construction the engineer shall fill out the Engineers Certificate of Completion (attached), and forward it to the Yuma County Department of Development Services. If all requirements have been completed this office will issue a Certificate of Approval of Construction.
3. Operation of a newly constructed facility shall not begin until this Department has issued a Certificate of Approval of Construction.
4. In accordance with the requirements of Arizona Administrative Code Section R18-4-119, fittings and valves shall conform to NSF Standard 61 and or bear the NSF-pw seal of approval.
5. A "Final Design Report" containing information as stipulated in *Engineering bulletin 10 chapter 1, section D.1*, shall be submitted to ADEQ and YCDDS by the engineer upon completion of the waterline. Use of the waterline is contingent upon approval of the "Final Design Report".

The State law, A.R.S. §49-104.B.10, requires that construction of the project must be in accordance with rules and regulations of the Arizona Department of Environmental Quality. If construction has not started within one year of the date of this approval, this certificate will be void and a written extension of time shall be required.

By:  R.S. June 24, 2008
Rick Stacks, R.S.
Environmental Health Manager